

Planning Department
Building and Safety Division

February 10, 1999

Studor, Inc.
2030 Main Street
Dunedin, Florida 34698
Attn: Michael Lopez

The City of Berkeley accepts Studor Air Admittance Valves based on the authority provided in Section 301.2 of the 1995 edition of the California Plumbing Code (CPC). The limitations and conditions are listed below:


1. In all cases and under all circumstances, use and installation of Studor Air Admittance Valves must conform to the restrictions stated within the manufacturer's installation instructions.
2. A schematic showing location of all Studor vents and conventional venting must be provided at plan check.
3. Studor must provide training in installation and use to the City of Berkeley building inspectors before the 1st installation of the products within the City.
4. There must be provided a main drain vent meeting the requirements of Section 904.1 of the 1995 CPC.
5. The water closets must have conventional vent piping complying with Table 7-5 of the 1995 CPC.
6. Air admittance valves shall not be used as vent terminals for vent stacks or stack vents.

The acceptance of Studor Air Admittance Valves is limited in use and to the provisions of the 1995 California Plumbing Code. If the company requests, a re-evaluation will be conducted after the adoption of the 1997 California Plumbing Code.

Stu dor, Inc.
Re: Stu dor Air Admittance Valves
Page 2

This acceptance may be revoked at any time, if there is reason to believe any material or device no longer conforms to the requirements on which its approval was based.

Yours very truly,



Hilary Herman
Acting Building Official

G:\CODES\LOGOS\HILARY.STU