

44-950 Eldorado Drive • Indian Wells, CA 92210-7497 Tel: 760/346-2489 • Fax: 760/346-0407 http://www.ci.indian-wells.ca.us



August 11, 1997

30 <sup>th</sup> Shiniversory 1967 - 1997

Mr. Michael Lopez Studor, Inc. 2030 Main Street Dunedin, Florida 34698

Dear Mr. Lopez:

The Studor air admittance values used as a vent terminal has been permitted in the City of Indian Wells on more than one occasion. The basis of approval was the documentation that was submitted with the application for permit. The items submitted were the approval reports from BOCA, SBCCI, and the ANSI reports. The installation of the Studor system was in accordance with the conditions and restrictions contained in the reports and the Studor literature. We maintain a complete library of the ICBO Evaluation Research reports, however, if Studor does not have an ICBO approval at the time of application, then the City of Indian Wells will accept other national standard approvals but those reports must be submitted with each application.

As of this date, we have had no system failures of the Studor products reported to our department. If you have any questions or need additional information, please call me or Mr. Jim Johnson.

Sincerely,

C:

Ronald L. Espalin, P.E.

**Building Official** 

Jim Johnson, Senior Building Inspector