



City of Palm Desert

73-510 FRED WARING DRIVE, PALM DESERT, CALIFORNIA 92260-2578

TELEPHONE (619) 346-0611

FAX (619) 341-7098

August 26, 1997

Studor Inc.
2030 Main Street
Dunedin, FL 34698

Attention: Michael Lopez

Dear Mr. Lopez:

Please accept this letter as confirmation that the City of Palm Desert's Department of Building and Safety will allow the installation of your Studor air admittance valve only with specific review and approval by this department. The situations which we will be allowing the use of this air admittance valve will be in special conditions where an atmospheric plumbing vent cannot be run through the roof due to structural conditions. Also, there may be a case where we would approve the use of your vent on residential remodels.

Whenever possible, we will continue to enforce the Uniform Plumbing Code and continue to require properly terminated plumbing vents.

Please inform your material suppliers that the plumbing contractor must get prior approval for the use of this product before the installation. If the city building inspector observes the installation of this air admittance valve without prior approval from this department, the job will not pass inspection and delays to the plumbing contractor may result.

Should you have any further questions regarding this matter, please feel free in contacting me.

Sincerely,

A handwritten signature in cursive script that reads "Pat Conlon".

PAT CONLON
DIRECTOR OF BUILDING AND SAFETY

PC:djw

cc: SOP File