



STATE OF MICHIGAN
DEPARTMENT OF LABOR & ECONOMIC GROWTH
LANSING

ROBERT W. SWANSON
DIRECTOR

JENNIFER M. GRANHOLM
GOVERNOR

July 24, 2006

Mr. Jack Beuschel
Studor, Inc.
11256 47th Street North
Clearwater, FL 33762

Dear Mr. Beuschel:

At the Construction Code Commission meeting on July 12, 2006, the Plumbing Division presented your request for approval of the Chem-Vent Air Admittance Valve, Model 20345.

The Construction Code Commission, upon recommendation of the State Plumbing Board, approved the use of the Chem-Vent Air Admittance Valve, Model 20345 with the following conditions:


1. All requirements of the Michigan Plumbing Code shall be applicable.
2. Shall be installed in accordance with manufacturer's installation instructions.
3. Each chemical waste system shall have a minimum of one chemical waste vent extended outdoors to the open air.

Should any change be made in the design or designation of these products the modified products must be submitted to this office, and a new acceptance obtained.

In accordance with Section 21 of Act 230 of the Public Acts of 1972, as amended, neither this letter nor the Certificate of Acceptability may be used for advertising or promotional purposes.

A Certificate of Acceptability is enclosed.

Sincerely,



Henry L. Green
Executive Director

HLG/mkr
Enclosure

cc: Duane Branch

Providing for Michigan's Safety in the Built Environment

BUREAU OF CONSTRUCTION CODES & FIRE SAFETY
P.O. BOX 30254 • LANSING, MICHIGAN 48909
Telephone (517) 241-9330 • Fax (517) 373-8547
www.michigan.gov

CERTIFICATE OF ACCEPTABILITY

NO. 1551 PA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, Act 230 of Public Acts of 1972, as amended, being Section 125.1521 of the Michigan Compiled Laws' on the recommendation of the State Plumbing Board.

MANUFACTURER: Studor, Inc.
11256 47th Street North
Clearwater, FL 33762


PRODUCT: Chem-Vent Air Admittance Valve, Model 20345


CONDITIONS OF USE AND INSTALLATION:

1. All requirements of the Michigan Plumbing Code shall be applicable.
2. Shall be installed in accordance with manufacturer's installation instructions.
3. Each chemical waste system shall have a minimum of one chemical waste vent extended outdoors to the open air.

THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.

By Direction of the Construction Code Commission


Henry L. Green, Executive Director


Robert G. Konyndyk, Chief Plumbing Division

Effective Date: July 12, 2006