

Design Specification Sheet

FR12 Fire Resistant Gas Box

IPS
CORPORATION®

202 Industrial Park Lane
Collierville, TN 38017
(901) 853-5001

Ratings: ASTM-E814 - 1 Hour (F), 1 Hour (T)
CAN/ULC - S115 1 Hour (F/FH), 1 Hour (FT/FTH)
ASTM-E814 - 2 Hour (F), 1.25 Hour (T)
CAN/ULC- S115 2 Hour (F/FH), 1.25 Hour (FT/FTH)
Firestop Device, Design No. IPS/PV 120-01

Models 82446 to 82454



1. Wall Construction

- Wood Or Steel Stud
- 1 Hour firewall construction consisting of each stud face being finished with 5/8 gypsum
- 2 Hour firewall construction consisting of each stud face being finished with 2 layers of 5/8 gypsum

2. Box Mounting

- Box should be securely fastened to stud with screws or nails
- Box units cannot be installed back to back within the same wall cavity

3. Piping Options

- Rigid or flexible metallic supply
- All plumbing within the wall must be secured

4. Valve Options

- CSA Listed Gas valve

5. Intumescent Pad

- The IPS FR12 Series Washer Box is manufactured from special frame resistant resin with an intumescent pad factory installed on the back of the box (do not remove).
- Gaps between the box and the gypsum may be filled up to ½" with dry wall plaster.

